MPD ECAL: Performance/Optimisation.

DUNE ND Workshop

Eldwan Brianne
DESY, 22nd October 2019

The Near Detector Hall.

The limited space

- The space in the near detector hall is very limited

- Imposes constrain on the side of the TPC + ECAL + Magnet

- The sizes:

  - TPC Radius 2.7 m / length 5 m

  - Magnet Radius 3.5 m

  - ➠ ~ 60-80 cm of space for the ECAL

 - ➠ ~ 60 cm for the muon tagger

**Bob Flight**

The MPD ECAL.

Roles and key numbers

- The role of the MPD ECAL

  - Identify neutral pions (NC background) - photon energy and angle measurement

  - Provide accurate timestamp of the event (TPC-ECAL track matching)

  - Particle ID via calorimetric variables and ToF

  - Bonus: Neutron energy reconstruction

- Typical photon energy range: ~few MeVs ⟹ small stochastic term needed

  - ~5-6%/Sqrt(E[GeV])

  - ~few deg /Sqrt(E[GeV])

- ⟹ drives longitudinal segmentation / granularity

- Neutrons ⟹ few 100 ps time resolution

Superconducting
Air Coil Magnet

HPgTPC

Calorimeter

The ECAL baseline design.
Geometry

- Octagonal geometry

- Small side length ~2.3m, Large side length ~2.6m, Width ~1.5m

- Total surface ~ 120 m^2 at inner face

- Total weight ~ 200t (Barrel) + ~95t (Endcap)

- Layers

  - High granular layers with tiles of 2.5x2.5x5 cm^3 readout with SiPM

  - Low granularity layers with strips of 4 cm width readout on both sides

- Absorber Cu

  - ~cm radiation length and "Small" moliere radius

    - ➡ thin absorber

   - ➡ larger spread of the shower along its main axis

The ECAL baseline design.
Performance

- Sampling structure

  - 2 mm Cu / 5 mm Sc

  - 8 high granularity layers (tiles) and 52 low granularity layers (strips)

- "Best" performance so far

  - ~5-6%/Sqrt(E)

  - ~6-7deg/Sqrt(E)

- Optimising based on this

  - Detector shape (polyhedra with more sides)

  - Absorber type Cu ➡ Pb

  - Granularity (cost driver)

  - Neutron detection (more CH, less Absorber in front)

χ^2 / ndf	25.05 / 11
A	0.0561 ± 0.001463
B	0.01496 ± 0.000683
C	0.04967 ± 0.00176

| χ^2 / ndf | 62.04 / 11 |
A	6.432 ± 0.1295
B	0.2819 ± 0.3635
C	3.886 ± 0.1689

Optimisation of the shape.
Geometry

- Baseline shape ➡ Octagon
  - Not optimal in between "2" cylinders
- Going for higher number of sides ➡ Dodecagonal
- Advantage
  - Can fit more layers in the same space
  - Shorter modules (shorter strips)
- Disadvantage
  - Slight increase in cost (see Frank's slides)
- Better Eres and Ares
  - Recover leakage with more layers. ~2-3% better at higher energies
  - Angular resolution better due to shorter strips?

Optimisation of the absorber.

Revisiting lead as absorber

- Decided to revisit Lead

- Can fit 8 HG layers and 82 LG layers + 2 thick slabs (130 mm) in the back

  - Increase from 1 λ to 1.5 λ (better for mu/pi ID)

- Sampling structure

  - 0.5 mm Pb / 3 mm Sc

- Energy resolution

  - Better at lower photon energies ➡ slight increase in sampling frequency

- Angular resolution

  - Way worse due to larger moliere radius (shower looks more "blobby")

  - Decrease of Sc thickness (analysis favors high energy depositions)

    - Will also impact neutron detection efficiency

- Does not look bad but

  - Need to increase Sc thickness

  - Limit number of additional layers to avoid increase of cost

Legend (top plot): σ_E/E vs Photon Energy [GeV]
- Baseline (60 layers) - 5.61 %/√E [GeV]
- Dodecagon Cu (80 layers) - 5.34 %/√E [GeV]
- Dodecagon Pb (80 layers) - 4.44 %/√E [GeV]

Legend (bottom plot): Angular resolution [deg] vs Photon Energy [GeV]
- Baseline (60 layers) - 6.43 deg/√E [GeV]
- Dodecagon Cu (80 layers) - 5.83 deg/√E [GeV]
- Dodecagon Pb (80 layers) - 9.11 deg/√E [GeV]

Optimisation of the granularity.

Going full strip

- What if we drop the high granular layers?
  - Main cost driver
- Different strip width from 40 mm to 20 mm
- Energy resolution
  - As expected not much change compare to the baseline
- Angular resolution
  - Worse (~10 deg @ 50 MeV to ~few deg at GeVs) for large strip widths
  - Can be "recovered" with smaller strip width (10-20 mm)
  - May be improved with shorter strips
- May be an option, however
  - Timing ➡ Need for fiberless + more transparent scintillator
  - Effect on neutrons?

Top plot legend:
- Baseline - 5.61 %/$\sqrt{E}$ [GeV]
- 40 mm Strips - 4.73 %/$\sqrt{E}$ [GeV]
- 30 mm Strips - 4.73 %/$\sqrt{E}$ [GeV]
- 20 mm Strips - 4.57 %/$\sqrt{E}$ [GeV]

y-axis: σ_E/E ; x-axis: Photon Energy [GeV]

Bottom plot legend:
- Baseline - 6.43 deg/$\sqrt{E}$ [GeV]
- 40 mm Strips - 6.47 deg/$\sqrt{E}$ [GeV]
- 30 mm Strips - 5.47 deg/$\sqrt{E}$ [GeV]
- 20 mm Strips - 4.85 deg/$\sqrt{E}$ [GeV]

y-axis: Angular Resolution [deg] ; x-axis: Photon Energy [GeV]

Neutron energy measurement.
Including backgrounds

- ECAL can be used for neutron energy reconstruction via ToF

  - Requires few tens ps time resolution

- Study with background done by Chris Marshall (See Chris's slides)

- Overall promising!

  - ~40% efficiency with ~40% purity

- Large amount of re-scatters (~50%) ➡ large tails in energy reconstruction and bias…

- Could be improved

  - Thicker scintillator slab in the front of the ECAL

  - Overall better absorber/Sc thickness ratio

True neutron KE (MeV)

$50 < T_n < 100$ MeV

1st scatter (56%) $\mu = -0.01$ $\sigma = 0.11$

Rescatter (44%) $\mu = -0.22$ $\sigma = 0.26$

(Reco - True) / True KE

Time-assisted π^0 reconstruction.

Ongoing work

- See Frank's slides

- Previous results showed that π^0 mass reconstruction (few %) and vertex position (~20-30 cm) is quite good

- Need to be redone in the current framework

- Use of timing to improve the vertex position reconstruction

- Time-assisted π^0 reconstruction

  - Use the high energetic photon and time to get a rough knowledge of the vertex position (~few tens of cm) along the axis

  - Use this to determine the axis of the other photon

  - Reconstruct the invariant mass and chi2 minimisation using the mass information to improve the vertex position

Design ideas.
A little of brainstorming from Sunday

- Improve neutron detection/resolution

  - Going fully active ➟ Thick scintillator slab before the ECAL but limited in space…

  - Increase Sc thickness (larger Abs/Sc ratio ➟ less re-scatters)

- Reduce cost (see Frank's slides)

  - Going full strips (small width to keep angular resolution)

  - Partially equip the MPD (need enough angular coverage to cover for the full muon kinematics) ➟ need some studies (amount of backscattered events)

    - Couple of timing layers upstream ➟ fast time-stamping and better LAr-MPD track matching

- Integration ECAL and Muon "tagger"

  - Thin ECAL with "best" energy/angular resolution with thick slabs in the back (most of photons are low energy)

  - Integration between the magnet coils

Towards a TDR.
Prototyping?

SMD SiPMs, modification of direct coupling

- More a discussion here than a plan
- CALICE has been working hard on developing high granular calorimeters
- No show-stopper in terms of technology
  - Well under control in CALICE (SiPM technology, plastic, light yield, uniformity, mass-production, QA)
  - Fast-timing (~< ns) will need more work
  - Recent AHCAL prototype (22k channels) using 3x3x3cm³ cells
  - CMS is building part of the HGCAL based on this technology
- All ingredients are technically in place
  - but dedicated funding is an issue

tailcatcher   AHCAL main stack

Conclusions.

and a look to the next year

- Baseline design (60 layers with Cu) will be the base for the CDR

- Optimisation of the ECAL is ongoing work

  - ECAL shape has limited influence (better containment)

  - Using Pb will heavily degrade the angular resolution (need much thinner Pb layers)

  - Granularity: going full strips is certainly an option but need to go to small width sizes (10-20 mm)

- The ECAL has a good (but not ideal?) neutron detection efficiency and energy reconstruction

- Analyses are ongoing work

  - pi0 reconstruction

  - physics

Backup Slides.

SiPM-on-Tile Technology

A closer look

- From the first large-scale application of SiPMs to the "***SiPM-on-tile***" technology

  2008 - 2016

Physics Prototype

Direct coupling of tiles and photon sensors

SMD SiPMs, modification of direct coupling

verification of tile performance in the lab

SiPM-on-Tile Technology
A closer look

- Mass production for a new 0.5 m^3, 22k channel prototype
 - 24k tiles produced & wrapped

injection molding
of PS based
scintillator tiles

09/2017

automatic placement of tiles on electronics
board (HBU), fully assembled with SiPMs
and ASICs

11/2017 - 02/2018

10/2017 - 01/2018

semi-automatic wrapping
of scintillator tiles

SiPM-on-Tile Technology
A closer look

- A multi-step QA procedure

gain @ vbr_mean+5

H_gain	
Entries	619
Mean	22.76
RMS	0.5745

spot testing of few % of 22k SiPMs, acceptance of 600 pc batches according to pre-defined criteria - all batches accepted

integration of layers & interfaces, test in beam at DESY

test and calibration of all channels with cosmics

test of all ASICs (~80-90% yield)

test of all assembled boards using built-in LEDs

SiPM-on-Tile Technology

A closer look

- In May and June 2018: Test beam at CERN SPS - the smoothest CALICE test beams ever.

electron shower

pion shower

online data

50 GeV electron beam with pion and muon contamination

muon track

- Analysis ongoing - first results soon